

Procedure for Gas Releases

Residential

1. A permit must be obtained by a licensed plumber. Any residential property that has a gas system that has been altered or repaired requires a gas test and must be inspected by the City of Glenpool before the gas utility provider will restore service.
2. Gas appliances that are the source of a gas leak do not require a gas test and do not have to be inspected by the city, however this should be checked out by a qualified person.
3. Where a gas service has been disconnected, a gas test and inspection by the City of Glenpool is usually required before gas utility provider will restore service.
4. All gas stops/valves must be installed and in working condition.
5. Prior to the release the lines test must hold the minimum pressure of 3 psi required by code for 10 minutes on a gauge that can be calibrated.

Commercial

1. A permit must be obtained by a licensed plumber. Any change of occupancy will require an inspection from the City of Glenpool.
2. Any Commercial property that has a gas system that has been altered or repaired will require a gas test and be inspected by the City of Glenpool before the gas utility provider will restore service.
3. Gas appliances that are the source of a gas leak do not require a gas test and do not have to be inspected, however this should be checked out by a qualified person.
4. Where a gas service has been disconnected due to a leak, or other reasons, a gas test and inspection by the City of Glenpool is usually required before Gas utility provider will restore service.
5. All gas stops/valves must be installed and in working condition.
6. Prior to the release the lines test must hold the minimum pressure of 3 psi for low pressure systems and 10 psi for high pressure systems, required by code for 10 minutes on a gauge that can be calibrated.
7. Required Annual gas test, call for procedure.